

Lead in Water Remediation Plan

Pursuant to the requirement of *Subpart 67-4: Lead Testing in School Drinking Water* the Ellenville Central School District tested all water outlets that could be used for drinking or cooking purposes. Some of these outlets tested above the 15 ppb action level. These outlets were taken out of service as soon as laboratory reports were received and reviewed by the district. Our remediation efforts are described below.

Remediation Key

A	Replaced plumbing components
B	Replaced plumbing fixture
C	Replaced plumbing fixture & accessible piping
D	Took fixture permanently of service

Elementary School

Location	Sample Result	Remediation	Follow-Up Sample Result
Room 596 Water Fountain	20	Took fixture out of service and will replace as part of Capital Project	
Room 570 Sink Faucet	57	Took fixture out of service and will replace.	
Room 310 Sink Faucet	23	Took fixture out of service and will replace as part of Capital Project	
Room 316 Sink Faucet	51	Took fixture out of service and will replace as part of Capital Project	
Room 316 Water Fountain	17	Took fixture out of service and will replace as part of Capital Project	
Room 332 Water Fountain	94	Took fixture out of service and will replace as part of Capital Project	